

EXACT EXCHANGER I N C O R P O R A T E D

December 15, 2017

Tescorp
PO Box 471453
Tulsa, OK 74147-1453

Dana,

For your record, all of the following SN's were tested successfully with dry Nitrogen at 1.1 x the design pressure of 25 PSIG and were held under pressure with no leaks for a minimum of 30 minutes.

Tescorp PO Number: F07160369
Job Number: 316014
Serial Numbers: 1609514, 1609515, 1610516, 1611517, and 1611518

Tescorp PO Number: F05170194
Job Number: 317018
Serial Numbers: 1706563, 1707564, 1708565, 1709566, 1710567, and 1711568

Should you have any questions please let us know.

Regards,
David Self